SACHIN G. BADWAIK
DFSET, DIS & DIPLOMA IN (FIRE SERVICE)
INDIVIDUAL MEMBER
FIRE & SECURITY ASSOCIATION OF INDIA
sgbadwaik@gmail.com
09850318191,09420866771

SAMIKSHA ENTERPRIZES

FIRE & SAFETY EQUIPMENTS SUPPLIERS & MAINTENANCE
Ganj Akhada Complex, Ramkrishna Nagar, Tumsar
District.: Bhandara (MH.)
MSME No.:- UNYAM-MH06-OOO3978
GeM Reg No.:- Y88M230007868851
GST No.:- 27ANVPB7787K1Z1
Rajendra Nagar, Balaghat Road, Tumsar District.: Bhandara - 441912

Ref. No. SET/F.M.D.Cer./2608/2025-26 Date : 15/07/2025

FIRE MOCK DRILL CERTIFICATE

Name Of Party :- **M/S. Principal, Shirinbhai Neterwala School**

Address:- **At.- Manek Nagar Dewadi, Tah.- Tumsar, District- Bhandara**

Date : **14/07/2025** Time : **4.30 PM** Shift : **Day**

Person conducting the drill: **School Staff & Student's**

Drill Location : **School Premises**

- **Fire Extinguisher Activation Method: 1]ABC [DCP] Type Fire Extinguisher Check for Green Zone indication On The pressure Gauge The Extinguisher is Ready and BC [CO2] Type HY. Tested to 250Kgf/cm2**

- **Fire Extinguisher Operating : ABC Type 1] Pull the Pin 2] Aim low at the base of fire 3] Squeeze the lever 4] Sweep back and fourth**

  BC CO2 Type 1] Keep the Extinguisher Upright and hold in Hand 2] Remove safety Pin and Turn the Whell anti – Clock Wise 3] Direct discharge at the bace of flames

- **Instruction: Fire Extinguisher After Use, Maintenance, Precautions, Record, Recharge**

Number of occupants evacuated : **School Staff & Student's** Total Time of Drill : **1 Hr.**

Fire Extinguisher Tested: **16 Nos.**

Verified by:
[SAMIKSHA ENTERPRIZES]

Authority Signature

Sachin Ghanshyam Badwaik
Digitally signed by Sachin Ghanshyam Badwaik
Date: 2025.07.16 11:46:17 +05'30'

SAMIKSHA ENTERPRISES SE TUMSAR


FIRE EXTINGUISHER


FIRE DETECTOR


SAFETY HELMET


FIRE BUCKET



FIRE HOSE PIPE


HOSE REAL BOX


FIRE SPRINKLER



FIRE BUZER


BRANCH PIPE NOZZLES

SACHIN G. BADWAIK
DFSET, DIS & DIPLOMA IN (FIRE SERVICE)
INDIVIDUAL MEMBER
FIRE & SECURITY ASSOCIATION OF INDIA
sgbadwaik@gmail.com
09850318191,09420866771

SAMIKSHA ENTERPRIZES

FIRE & SAFETY EQUIPMENTS SUPPLIERS & MAINTENANCE
Ganj Akhada Complex, Ramkrishna Nagar, Tumsar
District.: Bhandara (MH.)
MSME No.:- UNYAM-MH06-OOO3978
GeM Reg No.:- Y88M230007868851
GST No.:- 27ANVPB7787K1Z1
Rajendra Nagar, Balaghat Road, Tumsar District.: Bhandara - 441912

Ref. No. SET/ Ren. Cer /2604/2025-26 Date : 15/07/2025

RENEWAL CERTIFICATE

This is to Certify that following Old Fire Extinguisher Equipment's Servicing, Refilling, Maintains, H.P. Tested To 17.5 KGF/CM2 AS Per IS : 2190 & Checked by me or in presence of me found working order on Good Condition.

Name of Party :- M/S. PRINCIPAL, SHIRINBAI NETERWALA SCHOOL
At – Maneck Nagar, Tumsar, Tah. –Tumsar, Distt. – Bhandara

Affiliation No. :- 1130005 **Udise No.** :- 27100311903

Established Premises :- School Building

Sr. No.	Fire Extinguisher Equipment Type	Fire Extinguisher Equipment Capacity	Quantity In Nos.	Inspection & Servicing Date	Next Due Date For Servicing, Testing& Refilling	Remark
1	ABC [DCP]	04Kg.	06	15.07.2025	14.07.2026	Ok
2	ABC [DCP]	05Kg.	04	15.07.2025	14.07.2026	Ok
3	BC [DCP]	10Kg.	01	15.07.2025	14.07.2026	Ok
4	BC [CO2]	05Kg.	01	15.07.2025	14.07.2026	Ok
		Total	12			

Remark:-

1] This Certified One Year Valid Dt. 15.07.2025 To Dt. 14.07.2026

2] Emergency Call : Fire - 101, Ambulance – 108, Police - 100

SAMIKSHA ENTERPRISES SE TUMSAR

[SAMIKSHA ENTRPRIZES]
Authority Signature

Sachin Ghanshyam Badwaik
Digitally signed by Sachin Ghanshyam Badwaik
Date: 2025.07.16 10:45:40 +05'30'


FIRE EXTINGUISHER


FIRE DETECTOR


SAFETY HELMET


FIRE BUCKET



FIRE HOSE PIPE


HOSE REAL BOX


FIRE SPRINKLER



FIRE BUZER


BRANCH PIPE NOZZLES

SACHIN G. BADWAIK
DFSET, DIS & DIPLOMA IN (FIRE SERVICE)
INDIVIDUAL MEMBER
FIRE & SECURITY ASSOCIATION OF INDIA
sgbadwaik@gmail.com
09850318191,09420866771

SAMIKSHA ENTERPRIZES

FIRE & SAFETY EQUIPMENTS SUPPLIERS & MAINTENANCE
Ganj Akhada Complex, Ramkrishna Nagar, Tumsar
District.: Bhandara (MH.)
MSME No.:- UNYAM-MH06-OOO3978
GeM Reg No.:- Y88M230007868851
GST No.:- 27ANVPB7787K1Z1
Rajendra Nagar, Balaghat Road, Tumsar District.: Bhandara - 441912

Ref. No. SET/Ren.Cer./2606/2025-26

Date : 15/07/2025

RENEWAL CERTIFICATE

This is to Certify that following Old Fire Extinguisher Equipment's Servicing, Refilling, Maintains, H.P. Tested To 17.5 KGF/CM2 AS Per IS : 2190 & Checked by me or in presence of me found working order on Good Condition.

Name of party :- M/S. Principal, Shirinbhai Neterwala School
At. Manek Nagar [Dewadi], Tahsil- Tumsar, District :- Bhandara.

Owner :- Shri. Sudhish Gopinath Menon

Vehicle No. :- MH31DS 5078

Established Premises :- School Bus

Sr. No.	Fire Extinguisher Equipment Type	Fire Extinguisher Equipment Capacity	Quantity In Nos.	Inspection & Servicing Date	Next Due Date For Servicing, Testing& Refilling	Remark
1	ABC [DCP]	06 Kg.	01	15.07.2025	14.07.2026	Ok
2	ABC [DCP]	04 Kg.	01	15.07.2025	14.07.2026	Ok
	Total	10 Kg.	02			

Remark:-

1] This Certified One Year Valid Dt. :15.07.2025 To Dt. : 14.07.2026

2] Emergency Call : Fire - 101, Ambulance – 108, Police - 100

SAMIKSHA ENTERPRISES SE TUMSAR

[SAMIKSHA ENTERPRIZES]
Authority Signature
Sachin Ghanshyam Badwaik
Digitally signed by Sachin Ghanshyam Badwaik
Date: 2025.07.16 10:54:06 +05'30'


FIRE EXTINGUISHER

FIRE DETECTOR


SAFETY HELMET

FIRE BUCKET

FIRE HOSE PIPE

HOSE REAL BOX

FIRE SPRINKLER


FIRE BUZER

BRANCH PIPE NOZZLES